

Government of West Bengal
Irrigation & Waterways Directorate
Office of the Executive Engineer
Metropolitan Drainage Mechanical Division
Jalasampad Bhawan (4th floor), Salt Lake City, Kolkata-91
Email: mdmdiwd@gmail.com

Memo No:1957/1(3)/IT-1

Dated: -04.11.2025

Notice Inviting
Expression of Interest (EOI)/Budgetary Quotation

EOI No.: WBIW/EE/MDMD/e-EOI-01/2025-26

For the work of

“Complete rewinding and repairing work of one number 2.5 MVA ONAN type Transformer, Volts at No load - 33000/3450V, Amperes - 43.7/418 A, 3Ph., 50 Hz, Core and windings weight - 3200 kg, Weight of oil - 1600 kg/1850 Ltr, total weight - 7500 kg (make - Crompton Greaves) at Bagjola Pumping Station at Kultigong, Block & P.S-Harua, Dist- North 24 Parganas”.

| Sl No | Particulars | Details |
|-------|------------------------------------------|--------------------------|
| 01 | Start Date of download of EOI Document | 05.11.25 |
| 02 | Last date of submission of Queries | 10.11.25 |
| 03 | Pre bid meeting | 11.11.25 at 14.00 HRS |
| 04 | Date of corrigendum | 12.11.25 |
| 06 | Last Date and time for Submission of EOI | 24.11.25 up to 16.00 HRS |
| 07 | Date of opening of EOI | 24.11.25 at 16.30 HRS |

EoI No.: WBIW/EE/MDMD/e-EOI-01/2025-26

**NOTICE INVITING EoI FOR MOST SUITABLE TECHNICAL SPECIFICATIONS, BOQ
AND BUDGETARY QUOTES**

Online/offline bids are hereby invited by the Executive Engineer, Metropolitan Drainage Mechanical Division, Irrigation & Waterways Directorate on behalf of the Irrigation & Waterways Department of West Bengal through single stage offline sealed bid for obtaining most suitable Methodology, Technical specifications, BOQ and Budgetary quotes from all interested bidders/agencies/contractors within the country having Pre-Qualification (eligibility) credential for execution of works of similar nature and financial capabilities. The technical bid and the financial bid will determine the final selection and acceptance of price schedule, items of work, ToR, Specifications and even scope of work for framing of a DPR of the project mentioned later.

Participants may submit their bid along with all requisite documents and a covering letter duly signed by the authorized signatory on or before 24.11.2025 by 16.00 hrs., either online through the portal www.wbtenders.gov.in or offline in hard copy at the following address:

**“Office of the Executive Engineer
Metropolitan Drainage Mechanical Division
Jalasampad Bhawan (4th floor), Salt Lake City, Kolkata-91
Telephone No-03323345768, Email Id: mdmdiwd@gmail.com”**

CONTENTS

Section I

Notice Inviting Expression of Interest (EoI)

Section II

1. Introduction
2. Brief scope of the project
3. Eligibility criteria
4. Instructions to bidders
5. Scope of work
6. Declaration

Section III Annexure

1. Annexure A/1: Cover letter for Expression of Interest
2. Annexure A/2: Details of Representative from Bidder/Lead Member of Consortium
3. Annexure B/1: Technical Credentials of the Bidder and / or Consortium
(Form-1)
4. Annexure B/2: Approach and Methodology being adopted by the Bidder and / or Consortium (Form-2)
5. Annexure B/3: BOQ details with Estimated cost in item rate (as per Form-3)
6. Annexure C: Layout Drawings

SECTION – I
NOTICE INVITING EXPRESSION OF INTEREST (EoI)

EoI No.: WBIW/EE/MDMD/e-EOI-01/2025-26

Government of West Bengal
Irrigation & Waterways Directorate
Office of the Executive Engineer
Metropolitan Drainage Mechanical Division
Jalasampad Bhawan (4th floor), Salt Lake City, Kolkata-91
Email: mdmdiwd@gmail.com

Online/offline Expression of Interests (EoIs) are invited by Executive Engineer, Metropolitan Drainage Mechanical Division, Irrigation & Waterways Directorate from eligible registered firms for obtaining Methodology, Specifications, BOQ and (Proposed) Budgetary Quotes for the work of “**Complete rewinding and repairing work of one number 2.5 MVA ONAN type Transformer, Volts at No load - 33000/3450V, Amperes - 43.7/418 A, 3 Ph, 50 Hz, Core and windings weight - 3200 kg, Weight of oil - 1600 kg/1850 Ltr, total weight - 7500 kg (make - Crompton Greaves) at Bagjola Pumping Station at Kultigong, Block & P.S- Haroa, Dist- North 24 parganas**”

| | | |
|----|----------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 1. | EoI Document | The EoI document can be downloaded from www.wbiwd.gov.in or www.wbtenders.gov.in from 05.11.2025 onwards and may be submitted either online through www.wbtenders.gov.in or in hard copy at this office. |
| 2. | Last date and time for bid Submission. | 24.11.25 at 16:00 Hrs. |
| 3. | Bid Security. | NIL |

For any queries, bidder may contact this office before submission of online/offline bid through E-mail Id: mdmdiwd@gmail.com

SECTION - II

1.0 INTRODUCTION TO THE PROJECT

Bagjola Pumping station plays a vital role since its commissioning in discharging drainage and storm water of Panihati, Kamarhati, Baranagar, Dum-Dum, South Dum-Dum Municipalities and entire catchment area of Upper Bagjola Khal (9.23km length) and Lower Bagjola khal (28km length) and finally emptied its bulk in the river Bidyadhari. The capacity of the pump house 1650 cusecs comprising of 14 no. 100 cusec & 5 no. 50 cusec capacity pumps. The entire pumping station consists of pumping system, lubrication & cooling system, HT & LT electrical system. There are two no's 2.5 MVA ONAN type Transformer of 33kv/3.45kv and two no's 500 KVA 33kv/440v transformer. During this monsoon period a huge humming sound observed from one no 2.5 MVA, 33kv/3.45kv transformer. It may cause failure and hampered in pump operation, which needs immediate rectification/repairing. So for smooth and uninterrupted operation of pumps at Bagjola Pumping station complete rewinding and repairing work of the said 2.5 MVA Transformer urgently required.

1.1 LOCATION

The work is located at Kultigong, Block & P.S- Haroa, Dist- North 24 parganas, W.B.

1.2 OBJECTIVE

Objective of the work is to provide better and uninterrupted power supply to the Bagjola Drainage Pumping Station which will lead to significant improvement of environment quality in the adjoining catchment area as also the economic improvement of the community.

2.0 BRIEF SCOPE OF THE PROJECT:

The scope of work includes the

- A) Complete rewinding and repairing work of 2.5 MVA ONAN type Transformer, Volts at No load - 33000/3450V, Amperes - 43.7/418 A, 3Ph., 50 Hz, Core and windings weight - 3200 kg, Weight of oil - 1600 kg/1850 Ltr, total weight - 7500 kg (make - Crompton Greaves)
- i) Detanking & opening the assembly of core and windings from tank and dismantling of HV and LV coils.
 - ii) Rewinding and re insulation of all HV & LV coils of the transformer with supply of new copper wire/strip of similar size, design and insulation.
 - iii) Reassembly of HV and LV coils and cores after rewinding with new copper winding wires.
 - iv) Baking of core and coil assembly, box up the same with replacement of gaskets, washers, packing materials etc.
 - v) Checking and servicing of all the spares of the transformer.
 - vi) Painting of the transformer.
 - vii) Supply and filling of new transformer oil as per name plate of the transformer.
 - viii) Supply & fitting fixing of new Winding Temperature Indicator (WTI) & Oil Temperature Indicator (OTI) with repairing of marshaling box.

[Expression of Interest / budgetary quotation]

- ix) Reinstallation, final testing at site and commissioning the transformer after necessary rewinding/repairing works.
- B) Taking out of 2.5 MVA ONAN type Transformer from substation pedestal and dragging up to truck with hydra, manpower, loading unloading and transportation from Bagjola site, Kulti, Haroa, North 24 PGS to workshop in Kolkata for necessary repairing/rewinding work and return back to site after repairing/rewinding works.

The works include all Mechanical, electrical, instrumentation, control and other related work as per as details scope of this estimate. The works are to be executed as per technical specification enclosed a separate part of this estimate. The part of specification shall be read in conjunction with other parts such as specifications, technical data which provide further information and details.

The contractor shall confirm of having visited site and collected and verified the data relating to site condition. The contractor acknowledges that any failure to acquaint itself with all such data and information shall not relieve its responsibility. The contractor shall be responsible for overall verification of equipment under the scope of work eg. Make, Model, specifications and responsible for detailed design of mechanical and electrical works of the proposed pumping station. Compliances with these specifications does not limit the responsibility of the contractor for the overall performance of the pumping station. Contractor can offer changes in design for better performance. Justification of such changes shall be provided by the contractor. Such changes are subject to approval by E.I.C.

3 ELIGIBILITY CRITERIA/PRE-QUALIFICATION

While submitting the proposal, the bidder shall ensure that the bidder meets the conditions of eligibility as described below:

| Sl. No. | Eligibility criteria | Capability Assessment Documents |
|---------|-------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 1. | Should be registered in India | <ul style="list-style-type: none">• IT Return• GST No. (If applicable) |
| 2. | Technical Credentials | <ul style="list-style-type: none">• It is desirable to firm have experience in similar nature of works• Completion certificate, If any |

4.0 INSTRUCTIONS TO BIDDERS

Submission of Application

The EoI document can be downloaded from www.wbiwd.gov.in or www.wbtenders.gov.in from **05.11.2025** onwards and may be submitted either online through www.wbtenders.gov.in or in hard copy at this office.

[Expression of Interest / budgetary quotation]

Last date & time of submission of bid manually in drop box at office of Executive Engineer, Metropolitan Drainage Mechanical Division, is on **24.11.25 till 16:00 Hours (IST)**.

No processing fee or bid security (EMD) is required during submission of the bid.

The applicant bidders/contractors are advised to carefully read all the 'Terms & Conditions' contained in this EoI. They should particularly go through the minimum desired Pre-qualification (PQ) works credential & financial eligibility criteria and satisfy them for all the mandatory eligibility requirements. Bidders desirous of participating in the EoI and should submit bids only if they fulfill the minimum PQ eligibility criteria and are in possession of all the required PQ Credential documents "in original".

This EoI is not an agreement and is neither an offer nor invitation by 'The Authority' to the prospective Bidders or any other person to allot the project. The information contained in this EoI or subsequently provided to Bidder, whether verbally or in documentary or any other form by or on behalf of the 'Authority' or any of its employees or advisors, is provided to Bidder on the terms and conditions set out in this EoI and such other terms and conditions subject to which such information is provided. The purpose of this EoI is to provide interested parties with information that may be useful to them in making their financial offers (Bids) pursuant to this EoI. This EoI includes statements, which reflect various assumptions and assessments arrived at by the 'Authority' in relation to the Project. Such assumptions, assessments and statements do not purport to contain all the information that each Bidder may require. This EoI may not be appropriate for all persons, and it is not possible for the 'Authority', its employees or advisors to consider the objectives, financial situation and particular needs of each party who reads or uses this EoI. The assumptions, assessments, statements and information contained in the Bidding Documents, especially the Project Report/data may not be complete, accurate, adequate or correct. Each Bidder should, therefore, conduct its own investigations and analysis and should check the accuracy, adequacy, correctness, reliability and completeness of the assumptions, assessments, statements and information contained in this EoI and obtain independent advice from appropriate sources.

Information provided in this EoI to the Bidder(s) is on a wide range of matters, some of which may depend upon interpretation of law. The information given is not intended to be an exhaustive account of statutory requirements and should not be regarded as a complete or authoritative statement of law. The 'Authority' accepts no responsibility for the accuracy or otherwise for any interpretation or opinion on law expressed herein.

The 'Authority', its employees and advisors make no representation or warranty and shall have no liability to any person, including any Applicant or Bidder under any law, statute, rules or regulations or tort, principles of restitution or unjust enrichment or otherwise for any loss, damages, cost or expense which may arise from or be incurred or suffered on account of anything contained in this EoI or otherwise, including the accuracy, adequacy, correctness, completeness or reliability of the EoI and any assessment, assumption, statement or information contained therein or deemed to form part of this EoI or arising in any way for participation in this Bid Stage.

The 'Authority' also accepts no liability of any nature whether resulting from negligence or otherwise howsoever caused arising from reliance of any Bidder upon the statements contained in this EoI.

The 'Authority' may in its absolute discretion, but without being under any obligation to do so, update, amend or supplement the information, assessment or assumptions contained in this EoI.

[Expression of Interest / budgetary quotation]

The issue of this EoI does not imply that the 'Authority' is bound to select a Bidder or to appoint the Selected Bidder/Consortium or Contractor, as the case may be, for the Project and the 'Authority' reserves the right to reject all or any of the Bidders or Bids without assigning any reason whatsoever.

The Bidder shall bear all its costs associated with or relating to the preparation and submission of their Bid including but not limited to preparation, documentation, scanning uploading, expenses associated with any demonstrations or presentations which may be required by the 'Authority' or any other costs incurred in connection with or relating to its Bid. All such costs and expenses will remain with the Bidder and the 'Authority' shall not be liable in any manner whatsoever for the same or for any other costs or other expenses incurred by a Bidder in preparation or submission of the Bid, regardless of the conduct or outcome of the Bidding Process.

I&WD reserve the right to verify all statements, information and documents submitted by the applicant in response to the EoI Document. Failure of the I&WD to undertake such verification shall not relieve the applicant of its obligations or liabilities hereunder nor will it affect any rights of I&WD thereunder.

The EoI document shall be submitted by the bidder duly signed on each page of the document. In case the proposal is submitted on the document downloaded from official website, the applicant shall be responsible for its accuracy and correctness as per the version uploaded by I&WD and shall ensure that there are no changes caused in the content of the downloaded document. In case of any discrepancy between the downloaded or photocopied version of the EoI document and the original EoI document issued by the I&WD, the latter shall prevail.

The right to suspend the short-listing process or part of the process to accept or reject any or all applications at any stage of the process and / or to modify the process or any part thereof at any time without assigning any reason therefore is reserved by I&WD without any obligation or liability whatsoever.

The bid document should be sealed in single envelope marked with the address, Name of work and EoI notice No., Last Date and Time of submission, Date and time of opening, name and address of the applicant.

The bid document should contain the following documents attached as annexure:

1. Cover Letter (as per Annexure-A/1)
2. Details of Representative from Bidder/Lead Member of Consortium (as per Annexure-A/2)
3. Technical Credentials of the Bidder and / or Consortium (Form-1)
4. Approach and Methodology being adopted by the Bidder and / or Consortium (Form-2)
5. BOQ details with Estimated cost in item rate (as per Form-3)

If the envelope is not sealed and marked as instructed above, this office assumes no responsibility for the misplacement or premature opening of the contents of the Proposal submitted. This office is not responsible for the non-receipt or delayed receipt of bid document send through courier or post.

Note: -

The envelope shall contain EoI document, signed copy of budgetary quotes along with Annexure in the prescribed format.

The Proposal shall be made in the Forms specified in this EoI Document. Any attachment to such Forms must be provided on separate sheets of paper and only information that is directly relevant should be provided. This may include photocopies of the relevant pages of printed documents.

EoIs received by this office after the specified time on the due date shall not be eligible for consideration and shall be summarily rejected.

Executive Engineer is not bound to accept any EoI and reserve the right to accept or reject any EoI, and reserve the right to annul the selection process and reject all EoI at any time prior to the award of the selection without assigning any reason(s) whatever and without thereby incurring any liability towards the affected participant(s) on this ground.

5.0 DECLARATION

I/We have completely read and hereby accept the scope of work, requirements, terms & conditions.

Signature of bidders authorized

Representative with seal:

Full address:

SECTION - III

ANNEXURE – A/1

Cover letter for Expression of Interest

To,
The Executive Engineer
Metropolitan Drainage Mechanical Division,
Jalasampad Bhawan (4th floor), Salt Lake City, Kolkata-91
Telephone No-03323345768, Email Id: mdmdiwd@gmail.com
I & WD, Govt. of West Bengal

Sub: Submission of bid for obtaining Methodology, Technical Specification, BOQ and Budgetary Quote for the proposed work: Complete rewinding and repairing work of one number 2.5 MVA ONAN type Transformer, Volts at No load - 33000/3450V, Amperes - 43.7/418 A, 3 Ph, 50 Hz, Core and windings weight - 3200 kg, Weight of oil - 1600 kg/1850 Ltr, total weight - 7500 kg (make - Crompton Greaves) at Bagjola Pumping Station at Kultigong, Block & P.S- Haroa, Dist- North 24 parganas.

Dear Sir,

In response to the Invitation for Expressions of Interest (EoI) published on _____ bearing Ref. No. e.... **WBIW/EE/MDMD/e-EOI-01/2025-26** “Complete rewinding and repairing work of one number 2.5 MVA ONAN type Transformer, Volts at No load - 33000/3450V, Amperes - 43.7/418 A, 3 Ph., 50 Hz, Core and windings weight - 3200 kg, Weight of oil - 1600 kg/1850 Ltr, total weight - 7500 kg (make - Crompton Greaves) at Bagjola Pumping Station at Kultigong, Block & P.S- Haroa, Dist- North 24 parganas.”

I / We acknowledge that Executive Engineer will be relying on the information provided in the Bid and the documents accompanying the Bid for recommendation of the most suitable Methodology, Technical Specification, BOQ and Budgetary quotes for the aforesaid Project, and we certify that all information provided therein is true and correct; nothing has been omitted which renders such information misleading; and all documents accompanying the Bid are true copies of their respective originals.

I / We shall make available to the Executive Engineer any additional information it may find necessary or require to supplement or authenticate the Bid.

I / We acknowledge the right of the Executive Engineer to reject our Bid without assigning any reason or otherwise and hereby waive, to the fullest extent permitted by applicable law, our right to challenge the same on any account whatsoever.

I / We declare that:

- a) I / We have examined and have no reservations to the Bidding Documents, including any Addendum issued by the Authority; and
- b) I / We do not have any conflict of interest in accordance with the EoI document; and

I / We understand that you may cancel the Bidding Process at any time and that you are neither bound to accept any Bid that you may receive nor to invite the Bidders to Bid for the Project, without incurring any liability to the Bidders.

[Expression of Interest / budgetary quotation]

In the event of my / our being declared as the Recommended Bidder, I / we agree to enter into an Agreement in accordance with the documents that has been provided to me / us. We agree not to seek any changes in the aforesaid documents and agree to abide by the same.

I / We agree and understand that the Bid is subject to the provisions of the Bidding Documents. In no case, I / we shall have any claim or right of whatsoever nature if the Project / Agreement is not awarded to me / us or our Bid is not opened or rejected.

The estimated budgetary price has been quoted by me / us after taking into consideration all the terms and conditions stated in the EoI documents, our own estimates of costs including all direct and indirect tax liabilities and after a careful assessment of the site and all the conditions that may affect the project cost and implementation of the project.

I / We agree and undertake to abide by all the terms and conditions of the EoI document. In witness thereof, I / we submit this Bid under and in accordance with the terms of the EoI documents.

Yours faithfully,

(Signature, Name & Designation of the Authorized Signatory)

Date:

Place:

Name & Seal of Bidder

Details of Representative from Bidder/Lead Member of Consortium

| Part A: General Information of Bidding Companies/Agency | | |
|--------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------|--|
| 1 | Name of the Company/Agency | |
| 2 | Type of Organization | |
| 3 | Address of the registered office of the company/Agency | |
| 4 | Year incorporated | |
| 5 | Address for communication | |
| 6 | Contact person: Name Designation Phone No. Fax No. Mobile No. Email address | |
| General Information Subsidiary and Associated Companies (wherever applicable): | | |
| 1 | Name of the company | |
| 2 | Address of the registered office of the company/Agency | |
| 3 | Nature of Business | |
| 4 | Brief description of company (not more than 100 words) | |
| 5 | Any other information the bidder would like to include: | |
| Part B - Details of GST | | |
| 1 | GST Registration No. | |
| 2 | LUT No. for zero rated supply | |

(Form-1)

Technical Credentials of the Bidder and / or Consortium

| | |
|--------------------------------------------------------------|--|
| Name of Client (End User): | |
| Name of the Work: | |
| Nature of Work: | |
| Description of services performed by the company: | |
| Project Location: | |
| Name, e-mail ID, telephone no. and fax no. of client's | |
| Project Cost (Rs. in lakh) | |
| Start date and finish date of the services (month and year): | |
| Brief description of the Work: | |
| Notes: | |

- Use separate sheet for each Eligible Assignment.

(Form-2)

DESCRIPTION OF APPROACH AND METHODOLOGY, RESPONDING TO THE EOI SCOPE

A description of the approach, methodology and work plan for performing the assignment, including a detailed description of the proposed methodology and staffing for the assignment.

- ❖ Technical Approach and Methodology. {Please explain your understanding of the objectives of the assignment as outlined in the scope mentioned in the Expression of Interest (EOI) document, the technical approach, and the methodology you would adopt for implementing the tasks to deliver the expected output(s), and the degree of detail of such output. Please do not repeat/copy the EoI in here.}

Memo No: 1957/2(3)/1T-1

Dated: -04.11.2025

Copy Submitted for information and kind necessary action to: -

1. The Chief Engineer, Mechanical & Electrical, I&W Directorate, 2nd Floor, Jalsampad Bhawan, Govt of West Bengal.
2. The Superintending Engineer, Mechanical & Electrical Circle, I&W Directorate, 6th Floor, Jalsampad Bhawan, Govt of West Bengal.

Sd/-

Executive Engineer
Metropolitan Drainage Mechanical Division

I & W Dte., Govt. of West Bengal

Memo No: 1957/3(3)/1T-1

Dated: -04.11.2025

Copy forwarded for favour of kind information to:

1. The Assistant Engineer-I attached to Metropolitan Drainage Mechanical Division.
2. The Assistant Engineer -II, attached to Metropolitan Drainage Mechanical Division.
3. The Assistant Engineer -III, attached to Metropolitan Drainage Mechanical Division.
4. The Assistant Engineer/UPS, Metropolitan Drainage Mechanical Division.
5. The Divisional Accounts Officer, Metropolitan Drainage Mechanical Division.
6. Estimating Section, Metropolitan Drainage Mechanical Division.
7. Notice Board of Metropolitan Drainage Mechanical Division

Sd/-

Executive Engineer
Metropolitan Drainage Mechanical Division

I & W Dte., Govt. of West Bengal

Tender Inviting Authority: Executive Engineer, Metropolitan Drainage Mechanical Division

Name of Work: Complete rewinding and repairing work of one number 2.5 MVA ONAN type Transformer, Volts at No load - 33000/3450V, Amperes - 43.7/418 A, 3 Ph, 50 Hz, Core and windings weight - 3200 kg, Weight of oil - 1600 kg/1850 Ltr, total weight - 7500 kg (make - Crompton Greaves) at Bagjola Pumping Station at Kultigong, Block & P.S- Haroa, Dist- North 24 Parganas.

Contract No: WBIWEE/MDMD/e-EOI-01/2025-26

Name of the Bidder/ Bidding Firm / Company :

PRICE SCHEDULE

(This BOQ template must not be modified/replaced by the bidder and the same should be uploaded after filling the relevent columns, else the bidder is liable to be rejected for this tender. Bidders are allowed to enter the Bidder Name and Values only)

| Sl. No. | Item Description | Quantity | Units | Estimated Rate in Rs. P | BASIC RATE In Figures To be entered by the Bidder in Rs. P | GST (If applicable in Percentage) | TOTAL AMOUNT including taxes Rs. P | TOTAL AMOUNT In Words |
|-----------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------|-------|-------------------------|------------------------------------------------------------|-----------------------------------|------------------------------------|-----------------------|
| 1 | 2 | 4 | 5 | 6 | 7 | 8 | 12 | 13 |
| 1 | Complete rewinding and repairing work of 2.5 MVA ONAN type Transformer, Volts at No load - 33000/3450V, Amperes - 43.7/418 A, 3 Ph, 50 Hz, Core and windings weight - 3200 kg, Weight of oil - 1600 kg/1850 Ltr, total weight - 7500 kg (make - Crompton Greaves) i) Charges for detanking & opening the assembly of core and windings from tank and dismantling of HV and LV coils. ii) Charges for rewinding and re insulation of all HV & LV coils of the transformer with supply of new copper wire/strip of similar size, design and insulation. iii) Reassembly of HV and LV coils and cores after rewinding with new copper winding wires. iv) Baking of core and coil assembly, box up the same with replacement of gaskets, washers, packing materials etc . v) Checking and servicing of all the spares of the transformer. vi) Painting of the transformer. vii) Supply and filling of new transformer oil as per name plate of the transformer. viii) Supply & fitting fixing of new Winding Temperature Indicator (WTI) & Oil Temperature Indicator (OTI) with repairing of marshelling box. ix) Re installation, final testing at site and commissioning the transformer after necessary rewinding/repairing works. | 1.00 | Job | 0.00 | | | 0.00 | INR Zero Only |
| 2 | Taking out of 2.5 MVA ONAN type Transformer from substation pedestal and dragging upto truck with hydra, manpower, loading unloading and transportation from Bagjola site, Kult, Haroa, North 24 PGS to workshop in Kolkata for necessary repairing/rewinding work and return back to site after repairing/rewinding works. | 1.00 | Job | 0.00 | | | 0.00 | INR Zero Only |
| Total in Figures | | | | | | | 0.00 | INR Zero Only |
| Quoted Rate in Words | INR Zero Only | | | | | | | |