



Government of West Bengal
Irrigation & Waterways Directorate
Office of the Superintending Engineer, Mechanical & Electrical Circle
Jalasampad Bhawan(6th floor), Bidhannagar, Kolkata -700 091.
Ph. No. 033 23218430, e-mail. : tasemec2025@gmail.com

Memo No: 736 /8E-173

Date: 01.12.2025

4th CORRIGENDUM

e-NIT No : WBIW/EETAtoSE/MEC/eEOI-04/25-26

e-Tender ID: 2025_IWD_926515_1

Name of work: Construction of an 800 cusec storm water drainage pumping station along with allied Civil and electro-mechanical work over Howrah drainage Canal at Nazirganj HMC P.S Sankrail, Dist: Howrah.[PART-II(Estimate of M&E Works)].

The following modifications which are decided in the Pre-Bid meeting made for this e-EOI with immediate effect.

The Pump speed in the BOQ Sl. No.1, under SECTION-A(PUMP) should be identical with the motor speed of BOQ Sl. No. 6 under SECTION-B(MOTOR).

Another inclusion of **TEFC & IP55** should be read before CACW in the BOQ Sl. No. 6 under SECTION-B(MOTOR).


Other terms and conditions of this e-NIT remains unchanged. Details may be seen from the web site <https://wbtenders.gov.in> and www.wbiwd.gov.in


Executive Engineer & TA to
Superintending Engineer
Mechanical & Electrical Circle

01/12/25

Copy submitted for favour of kind information to:

- 1 The Chief Engineer, Mechanical & Electrical, I&W Department, Govt of West Bengal.
- 2 The Superintending Engineer, Mechanical & Electrical Circle, I&W Dte.
- 3 The Executive Engineer, Metropolitan Electrical Division, I&W Dte
- 4 Nodal officer of e-Tendering. Irrigation & Waterways Department Jalasampad Bhawan, 7th Floor, Salt Lake City, Kolkata-700091 through e-mail dvcsc6816@gmail.com with the request to publish in the Departmental website: wbiwd.gov.in


Executive Engineer & TA to
Superintending Engineer
Mechanical & Electrical Circle

01/12/25



Government of West Bengal
Irrigation & Waterways Directorate
Office of the Superintending Engineer, Mechanical & Electrical Circle
Jalasampad Bhawan (6th floor), Bidhannagar, Kolkata -700 091.
Ph. No. 033 23218430, e-mail : tasemec2025@gmail.com

Memo No: 752 /8E-173

Date: 05.12.2025

5th CORRIGENDUM

e-NIT No : WBIW/EETAtoSE/MEC/eEOI04/25-26

e-Tender ID: 2025_IWD_926515_1

Name of work: Construction of an 800 cusec storm water drainage pumping station along with allied Civil and electro-mechanical work over Howrah drainage Canal at Nazirganj HMC P.S Sankrail, Dist: Howrah.[PART-II(Estimate of M&E Works)].

The following modification is made for this e-EOI with immediate effect in respect of BOQ serial no 2(g) and 6.

SLNo.	Existing as	To be read as
2(g)	Motor speed = 360 r.p.m.(Maximum)	Maximum RPM of the pump shall be calculated in the compliance with point no (j) of 2.2.2.1 inclusive of other relative points under USOR (M & E), I & W Department immediately.
6	Motor speed = 360 r.p.m.(Maximum)	Maximum RPM of the pump shall be calculated in the compliance with point no (j) of 2.2.2.1 inclusive of other relative points under USOR (M & E), I & W Department immediately.

Other terms and conditions of this e-NIT remains unchanged. Details may be seen from the web site <https://wbtenders.gov.in> and www.wbiwd.gov.in.

o/c


Executive Engineer & TA to
Superintending Engineer
Mechanical & Electrical Circle

Date: 05.12.2025

Memo No: 752/1(4)/8E-173


Copy submitted for favour of kind information to:


05/12/25

1. The Chief Engineer, Mechanical & Electrical, I&W Department, Govt of West Bengal.
2. The Superintending Engineer, Mechanical & Electrical Circle, I&W Dte.
3. The Executive Engineer, Metropolitan Electrical Division, I&W Dte.
4. Nodal officer of e-Tendering, Irrigation & Waterways Department Jalasampad Bhawan, 7th Floor, Salt Lake City, Kolkata-700091 through e-mail dvsc6816@gmail.com with the request to publish in the Departmental website: wbiwd.gov.in.

o/c


Executive Engineer & TA to
Superintending Engineer
Mechanical & Electrical Circle


05/12/25